

Appendix 1 – Price grid - Evaluation scenario

(Failure to complete this Appendix may lead to the rejection of the tender)

PRICE LIST

	LIST OF MATERIAL AND WORK TO BE PERFORMED	UNIT PRICE	PRICE SCENARIO the replacement of the existing tubes into LED type in 4 standard offices (6 tubes in each room) in the EMSA building	PRICE OF THE BID for evaluation purposes (unit price x scenario)
A.	Complete replacement works (per 1 tube), including: <ul style="list-style-type: none">• removal of existing fluorescent tube 35W and transport to certified destruction dump,• installation of new LED type tube,• verification of the dimming function and DALI controlling,• adaptation of electrical cabling connections (if needed) with existing control appliances.	...	A x 24	...
B.	Supply of T5 LED tube, length 1449mm, maximum power 15W, DALI, colour temperature neutral white (4000K +/- 200K) with power factor >0.9 (min. requirement as per point 2 of Tender Specification)	...	B x 24	...
	Total price of the bid for evaluation purposes (A x 24 + B x 24) =			...